

KABLO SEÇİM CETVELİ - 1

| DİREK KALKIŞ | | | | | | | | | | | | | | |
|--------------------------|------|----------------------------|-------------------------------------|-----|-----|-----|-----|-----|--|--|--|--|--|--|
| GÜÇ | | V O L T A J | KABLO KESİDİ 3 X ...mm ² | | | | | | | | | | | |
| HP | KW | | 1,5 | 2,5 | 4 | 6 | 10 | 16 | | | | | | |
| MAKSİMUM UZUNLUK (METRE) | | | | | | | | | | | | | | |
| 0,5 | 0,37 | 220 V | 80 | 130 | | | | | | | | | | |
| 0,75 | 0,55 | | 55 | 90 | 140 | | | | | | | | | |
| 1 | 0,75 | | 40 | 80 | 105 | 160 | | | | | | | | |
| 1,5 | 1,10 | | 30 | 50 | 75 | 115 | 190 | | | | | | | |
| 2 | 1,50 | | 20 | 35 | 60 | 90 | 145 | 235 | | | | | | |
| 3 | 2,20 | | | 30 | 50 | 70 | 120 | 185 | | | | | | |
| | | | | | | | | | | | | | | |

| DİREK KALKIŞ | | | | | | | | | | | | | | | | | |
|--------------------------|------|----------------------------|-------------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| GÜÇ | | V O L T A J | KABLO KESİDİ 3 X ...mm ² | | | | | | | | | | | | | | |
| HP | KW | | 2,5 | 4 | 6 | 10 | 16 | 25 | 35 | 50 | 70 | 95 | 120 | 150 | | | |
| MAKSİMUM UZUNLUK (METRE) | | | | | | | | | | | | | | | | | |
| 3 | 2,2 | 380 V | 190 | 300 | 460 | | | | | | | | | | | | |
| 4 | 3 | | 150 | 240 | 360 | | | | | | | | | | | | |
| 5,5 | 4 | | 110 | 170 | 260 | 450 | | | | | | | | | | | |
| 7,5 | 5,5 | | 80 | 130 | 190 | 340 | 540 | | | | | | | | | | |
| 10 | 7,5 | | 60 | 100 | 150 | 250 | 410 | | | | | | | | | | |
| 12,5 | 9,2 | | 50 | 80 | 120 | 205 | 330 | 510 | | | | | | | | | |
| 15 | 11 | | | 60 | 100 | 170 | 280 | 440 | | | | | | | | | |
| 17,5 | 13 | | | | 90 | 150 | 245 | 385 | | | | | | | | | |
| 20 | 15 | | | | 80 | 130 | 210 | 330 | 460 | 660 | | | | | | | |
| 25 | 18,5 | | | | | 100 | 170 | 260 | 370 | 530 | | | | | | | |
| 30 | 22 | | | | | 90 | 140 | 220 | 310 | 440 | | | | | | | |
| 35 | 26 | | | | | | 120 | 190 | 270 | 380 | 540 | | | | | | |
| 40 | 30 | | | | | | 100 | 170 | 230 | 330 | 460 | | | | | | |
| 50 | 37 | | | | | | | 130 | 190 | 270 | 380 | 520 | | | | | |
| 60 | 45 | | | | | | | | 110 | 160 | 230 | 320 | 440 | 550 | | | |
| 70 | 52 | | | | | | | | | 140 | 200 | 280 | 385 | 480 | | | |
| 75 | 55 | | | | | | | | | 120 | 170 | 240 | 330 | 410 | 530 | | |
| 80 | 59 | | | | | | | | | 115 | 160 | 230 | 310 | 390 | 500 | | |
| 90 | 66 | | | | | | | | | 110 | 150 | 220 | 290 | 370 | 470 | | |
| 100 | 75 | | | | | | | | | 96 | 140 | 190 | 270 | 330 | 425 | | |
| 110 | 81 | | | | | | | | | | 125 | 175 | 245 | 300 | 380 | | |
| 125 | 92 | | | | | | | | | | 110 | 160 | 220 | 275 | 340 | | |
| 150 | 110 | | | | | | | | | | | 130 | 180 | 220 | 290 | | |
| 180 | 132 | | | | | | | | | | | | 150 | 190 | 240 | | |
| 200 | 150 | | | | | | | | | | | | | 130 | 170 | 220 | |
| 225 | 165 | | | | | | | | | | | | | | 125 | 150 | 190 |
| 250 | 185 | | | | | | | | | | | | | | | | 170 |
| 275 | 200 | | | | | | | | | | | | | | | | 160 |

TABLODA BELİRTİLEN MAKSİMUM KABLO UZUNLUKLARI % 3 LÜK VOLTAJ DÜŞMESİ TEMEL ALINARAK VE 25 °C SICAKLIKTAKI HESAPLANMIŞTIR.

KABLO SEÇİM CETVELİ - 2

| YILDIZ ÜÇGEN | | | | | | | | | | | | | | | |
|--------------------------|------|----------------------------|-------------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| GÜÇ | | V O L T A J | KABLO KESİDİ 3 X ...mm ² | | | | | | | | | | | | |
| HP | KW | | 1,5 | 2,5 | 4 | 6 | 10 | 16 | 25 | 35 | 50 | 70 | 95 | 120 | 150 |
| MAKSİMUM UZUNLUK (METRE) | | | | | | | | | | | | | | | |
| 4 | 3 | 380 V | 140 | 230 | 370 | | | | | | | | | | |
| 5,5 | 4 | | 100 | 170 | 270 | 400 | | | | | | | | | |
| 7,5 | 5,5 | | 70 | 120 | 200 | 300 | 500 | | | | | | | | |
| 10 | 7,5 | | 57 | 90 | 150 | 220 | 380 | | | | | | | | |
| 12,5 | 9,2 | | 46 | 70 | 120 | 180 | 310 | 490 | | | | | | | |
| 15 | 11 | | 39 | 60 | 100 | 150 | 260 | 400 | | | | | | | |
| 17,5 | 13 | | | 55 | 90 | 130 | 230 | 355 | | | | | | | |
| 20 | 15 | | | 50 | 80 | 110 | 200 | 310 | 490 | | | | | | |
| 25 | 18,5 | | | | 60 | 90 | 160 | 250 | 400 | 560 | | | | | |
| 30 | 22 | | | | 50 | 70 | 130 | 210 | 340 | 470 | | | | | |
| 35 | 26 | | | | 46 | 68 | 110 | 180 | 290 | 410 | | | | | |
| 40 | 30 | | | | | 60 | 100 | 160 | 250 | 360 | 500 | | | | |
| 50 | 37 | | | | | 40 | 80 | 130 | 200 | 290 | 410 | | | | |
| 60 | 45 | | | | | | 70 | 110 | 170 | 240 | 350 | 480 | | | |
| 70 | 52 | | | | | | | 95 | 150 | 210 | 305 | 420 | | | |
| 75 | 55 | | | | | | | 80 | 130 | 180 | 260 | 360 | 500 | | |
| 80 | 59 | | | | | | | | 120 | 170 | 245 | 340 | 475 | | |
| 90 | 66 | | | | | | | | 110 | 160 | 230 | 320 | 450 | 520 | |
| 100 | 75 | | | | | | | | 100 | 150 | 200 | 290 | 380 | 440 | 540 |
| 110 | 81 | | | | | | | | | 135 | 185 | 260 | 340 | 405 | 495 |
| 125 | 92 | | | | | | | | 120 | 170 | 230 | 300 | 370 | 450 | |
| 150 | 110 | | | | | | | | 100 | 140 | 200 | 250 | 300 | 370 | |
| 180 | 132 | | | | | | | | | 120 | 165 | 210 | 260 | 310 | |
| 200 | 150 | | | | | | | | | | 150 | 190 | 230 | 280 | |
| 225 | 165 | | | | | | | | | | 130 | 170 | 200 | 240 | |
| 250 | 185 | | | | | | | | | | 125 | 160 | 190 | 230 | |
| 275 | 200 | | | | | | | | | | | 140 | 170 | 200 | |
| 300 | 220 | | | | | | | | | | | | | 120 | |

TABLODA BELİRTİLEN MAKSİMUM KABLO UZUNLUKLARI % 3 LÜK VOLTAJ DÜŞMESİ TEMEL ALINARAK VE 25 °C SICAKLIKTA HESAPLANMIŞTIR.